



**WORLD
AQUATICS**

DIVING EVENT CERTIFICATION

ORGANIZING BODY
BUILDING NAME
OWNER
CONTRACTOR
DESIGN TEAM
DATE

WORLD AQUATICS
APPROVED BY
DATE
SIGNATURE

MEASUREMENT CRITERIA

1. DIVING MEASUREMENTS SHALL BE TAKEN WITH THE POOL FULL OF WATER.
2. THE WATER TEMPERATURE SHALL NOT BE LESS THAN 28° CENTIGRADE PER PART 4, 13.1.5.

SPRINGBOARD DIVING

PART 4, 13.1.1.1 - The springboards shall be at least 4.88m long and 0.5m wide. At all World Aquatics Events, the type of springboard which must have a slip-resistant surface shall be approved by World Aquatics.

WORLD AQUATICS RULE	COMPLIANT	NONCOMPLIANT
PART 4, 13.1.1.1		

PART 4, 13.1.1.2 - The springboards shall be provided with movable fulcrums easily adjustable by the diver.

WORLD AQUATICS RULE	COMPLIANT	NONCOMPLIANT
PART 4, 13.1.1.2		

PART 4, 13.1.1.4 - The minimum distance recommended from the rear to the centre line of the fulcrum shall be in accordance with the recommendation or specification of the springboard manufacturer.

WORLD AQUATICS RULE	COMPLIANT	NONCOMPLIANT
PART 4, 13.1.1.4		

PART 4, 13.1.1.5 - The springboards shall be installed dead level at the leading edge when the movable fulcrum is in all positions.

WORLD AQUATICS RULE	COMPLIANT	NONCOMPLIANT
PART 4, 13.1.1.5		

PART 4, 13.1.1.6 - The springboards should be placed on either one or both sides of the platform. For Synchronised Diving, it is required that at least two springboards at the same height shall be placed side by side and no objects should obstruct the visibility in any part of the dive between the divers. See Diving Diagrams PART 4, 13.5 Appendix 1 and PART 4, 13.5 Appendix 2.

WORLD AQUATICS RULE	COMPLIANT	NONCOMPLIANT
PART 4, 13.1.1.6		

PLATFORM DIVING

PART 4, 13.1.2.1 - Each platform shall be rigid and horizontal.

WORLD AQUATICS RULE	COMPLIANT	NONCOMPLIANT
PART 4, 13.1.2.1		

PART 4, 13.1.2.4 - The surface and the front edge of the platform shall be covered throughout with a resilient slip-resistant surface. The two surfaces shall be covered separately in order to achieve a clean 90° angle or as described in PART 4, 13.1.2.3. The front surface is to be applied first and then the top surface.

The platforms shall be covered in a slip-resistant material that shall have a tread pattern that provides sufficient traction in wet and dry conditions such that the divers are prevented from slipping when performing dives in all directions. The minimum thickness must be 6mm (- 0 / + 1mm) and the colour should give a contrast to the surrounding décor. The material shall be easily cleaned to maintain the anti-slip feature of the product.

WORLD AQUATICS RULE	COMPLIANT	NONCOMPLIANT
PART 4, 13.1.2.4		

PART 4, 13.1.2.8 - Each platform shall be accessible by suitable stairs (not ladders) as required by the countries building regulations and or health and safety standards that are applicable.

WORLD AQUATICS RULE	COMPLIANT	NONCOMPLIANT
PART 4, 13.1.2.8		

GENERAL REQUIREMENTS

PART 4, 13.1.3.1 - For pools designed and constructed after 26th September 2013 the minimum dimensions in metres for diving facilities as detailed on the “Diving Facilities Diagram” in PART 4, 13.5 Appendix 1 and PART 4, 13.5 Appendix 2 shall prevail, using, as a basic measuring point of reference, the plummet line, which is a vertical line extending through the centre of the front edge of the springboard or platform. It is recommended that the preferred dimensions be used for projects considered to have an important status.

If no damage or renovation has occurred since the submission of the Diving Pool Certification, measurements from that document shall be accepted.

WORLD AQUATICS RULE	COMPLIANT	NONCOMPLIANT
PART 4, 13.1.3.1		

PART 4, 13.1.3.10 - Mechanical surface agitation shall be installed under the diving facilities to aid the divers in their visual perception of the surface of the water. In pools equipped with an underwater bubble machine, the machine should only be used for this purpose if it creates sufficient water agitation when working with a very low pressure; otherwise a horizontal water sprinkler system should only be used.

WORLD AQUATICS RULE	COMPLIANT	NONCOMPLIANT
PART 4, 13.1.3.10		

PART 4, 13.1.4.1 - The minimum illumination at a level of 1m above the water surface shall not be less than 600 lux. A lighting report shall be issued in addendum with this document.

WORLD AQUATICS RULE	COMPLIANT	NONCOMPLIANT
LIGHTING REPORT ISSUED		
PART 4, 13.1.4.1		

PART 4, 13.1.4.2 - Sources of natural and artificial illumination shall be provided with controls to prevent glare.

WORLD AQUATICS RULE	COMPLIANT	NONCOMPLIANT
PART 4, 13.1.4.2		

PART 4, 13.1.5 - The water temperature shall be not less than 28° Celsius.

WORLD AQUATICS RULE	COMPLIANT	NONCOMPLIANT
PART 4, 13.1.5		

DIVING FACILITIES FOR OLYMPIC GAMES AND WORLD CHAMPIONSHIPS

PART 4, 13.2.3 - For Olympic Games and World Aquatics Championships, PART 4, 13.1.3 in total shall apply.

WORLD AQUATICS RULE	COMPLIANT	NONCOMPLIANT	NOT APPLICABLE
PART 4, 13.2.3			

PART 4, 13.2.4 - The light intensity at the level of 1m above the water surface shall not be less than 1500 lux.

WORLD AQUATICS RULE	COMPLIANT	NONCOMPLIANT	NOT APPLICABLE
PART 4, 13.2.4			

ADDITIONAL COMMENTS

THIS SECTION IS PROVIDED FOR ADDITIONAL COMMENTS:

SIGNATURES

FACILITY NAME			
SURVEYOR		SIGNATURE	
POOL EXPERT		SIGNATURE	
ORGANIZING BODY		SIGNATURE	
FEDERATION			
POOL NUMBER		DATE	